

| Number | Sample Number | Fixture Type | Sample Location | Lead Limit | Result LEAD | lead Retes | Copper Limit | Result COPPER | Copper Retest |
|--------|---------------|-------------------|-----------------|------------|-------------|------------|--------------|---------------|---------------|
| 1 | FGCS-DWS-01 | Classroom Sink | | 15 | 2.6 | | 1300 | 62.8 | |
| 2 | FGCS-DWF-02 | Drinking Fountain | | 15 | 0.3 | | 1300 | 46.5 | |
| 3 | FGCS-DWF-03 | Drinking Fountain | | 15 | 6.7 | 0.4 | 1300 | not detected | 5.8 |
| 4 | FGCS-DWS-04 | Lunch Room Sink | | 15 | 4.6 | | 1300 | 85.4 | |
| 5 | FGCS-DWS-05 | Lunch Room Sink | | 15 | 4.2 | | 1300 | 120 | |
| 6 | FGCS-DWSC-06 | Lunch Room Sink | | 15 | 1.4 | | 1300 | 31.2 | |
| 7 | FGCS-DWSH-07 | Classroom Sink | | 15 | 1.8 | | 1300 | 76.8 | |
| 8 | FGSC-DWSC-08 | Classroom Sink | | 15 | 1 | | 1300 | 105 | |
| 9 | FGSC-DWSH-09 | Classroom Sink | | 15 | 0.8 | | 1300 | 23.9 | |
| 10 | FGSC-DWS-10 | Classroom Sink | | 15 | 2.1 | | 1300 | 49.8 | |
| 11 | FGSC-DWF-11 | Drinking Fountain | | 15 | 0.6 | | 1300 | 434 | |
| 12 | FGCS-DWF-12 | Drinking Fountain | | 15 | 0.3 | | 1300 | 7.8 | |
| 13 | FGCS-DWS-13 | Classroom Sink | | 15 | 6.2 | 6.9 | 1300 | 80.9 | 101 |
| 14 | FGCS-DWS-14 | Classroom Sink | | 15 | 2 | | 1300 | 59.6 | |
| 15 | FGCS-DWSC-15 | Classroom Sink | | 15 | 7.5 | 2.1 | 1300 | 89.3 | 12.7 |
| 16 | FGSC-DWSC-16 | Classroom Sink | | 15 | 2.0 | | 1300 | 80.2 | |

