

Number	Sample Number	Fixture Type	Sample Location	Lead Limit	Result LEAD	Lead Retest	Copper Limit	Result COPPER	Copper Retest
1	FGCS-DWS-01	Mixed sink	Art Room	15	2.6		1300	62.8	
2	FGCS-DWF-02	Fountain	Hallway	15	0.3		1300	46.5	
3	FGCS-DWF-03	Fountain	Hallway	15	6.7	0.4	1300	not detected	5.8
4	FGCS-DWS-04	Mixed Sink	Classroom 1	15	4.6		1300	85.4	
5	FGCS-DWS-05	Mixed sink	Classroom 2	15	4.2		1300	120	
6	FGCS-DWSC-06	Sink cold	Classroom 3	15	1.4		1300	31.2	
7	FGCS-DWSH-07	Sink hot	Classroom 3	15	1.8		1300	76.8	
8	FGSC-DWSC-08	Sink cold	Staff room	15	1		1300	105	
9	FGSC-DWSH-09	Sink hot	Staff room	15	0.8		1300	23.9	
10	FGSC-DWS-10	Mixed sink	Staff room	15	2.1		1300	49.8	
11	FGSC-DWF-11	Fountain	Basement hallway	15	0.6		1300	434	
12	FGCS-DWF-12	Fountain	Basement hallway	15	0.3		1300	7.8	
13	FGCS-DWS-13	Mixed sink	Classroom 4	15	6.2	8.9	1300	80.9	101
14	FGCS-DWS-14	Mixed sink	Classroom 5	15	2		1300	59.6	
15	FGCS-DWSC-15	Sink cold	Classroom 6	15	7.5	2.1	1300	89.3	12.7
16	FGSC-DWSC-16	Sink hot	Classroom 6	15	3.9		1300	89.2	

